

A	B	C	D	E	F	G	H	I	J	K	L
DG Node		DG in Base Portfolio/ POU forecast	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2024 Unassigned PDGD	Total Additional DG Modeled	Total DG Deliverable	2024-2025 PDGD	Notes
Substation Name	Transmission Level kV		EO	FC	EO	FC					
Barre	230		0	0			20		20	20	
Rector	230		7	4.8			3		0	3	behind North of Magunden constraint, no deliverability available
Laguna Bell	66	10	4.9	0			10		10	10	
Lewis	230		0	0			18		18	18	
Rio Hondo	230		1.1	0			5.2		5.2	5.2	
Kramer	115	8.00									Merchant zone, no deliverability available
Valley	500	1.25									Merchant zone, no deliverability available
Etiwanda Substation	230	0.08									Merchant zone, no deliverability available
Etiwanda Substation	230	0.51									Merchant zone, no deliverability available
Orangecrest Substation	12	5.00									Merchant zone, no deliverability available
Goodrich	230	125.00									behind Lugo-Victorville constraint, no deliverability available