

Wind and Solar Curtailment May 06, 2025

This report is produced daily to provide a detailed accounting of the wind and solar renewable generation that was curtailed and the reasons why¹. This report should be read in the context of the Renewables Watch report for a more complete understanding of both renewable curtailment and generation².

Wind and solar curtailments are grouped into the following categories:

1. Economic - Local: Market dispatch of generators with economic bids to mitigate local congestion³.
2. Economic - System: Market dispatch of generators with economic bids to mitigate system-wide oversupply⁴.
3. SelfSchCut - Local: Market dispatch of self-schedules to mitigate local congestion.
4. SelfSchCut - System: Market dispatch of self-schedules to mitigate system-wide oversupply.
5. ExDispatch - Local: Exceptional dispatch to mitigate local congestion.
6. ExDispatch - System: Exceptional dispatch to mitigate system-wide oversupply.

Note: Amounts smaller than 1 MW are filtered out for simplicity. Such small curtailments are occasionally observed when forecasts are lower than Pmin when market will de-commit the unit and send the 0 MW dispatch.





¹Only wind and solar resources can be reported in this manner because these resources have a forecast. Curtailment is defined as the difference between actual production and the forecast when actual production is less than the forecast.

²The Renewables Watch report provides daily actual renewable production within the ISO grid. It is available at: <http://www.caiso.com/green/renewableswatch.html>.


³Congestion occurs when available, least-cost energy cannot be delivered to some loads because transmission facilities do not have sufficient capacity to deliver the energy.

⁴For more information on oversupply conditions, please see: http://www.caiso.com/Documents/FlexibleResourcesHelpRenewables_FastFacts.pdf


The following charts show the daily and 7-day wind and solar curtailment by category, if any.



The following charts show hourly year to date wind and solar curtailment by category, if any.



The following charts show monthly year to date wind and solar curtailment by category, if any.



TYPE	YTD CURTAILED MWH - 5/6/2025
LocalEconomic	1,823,117
LocalSelfSchCut	782
SystemEconomic	502,739
TOTAL	2,326,638

Data used to produce hourly chart

DATE	HOUR	CURT TYPE	REASON	FUEL TYPE	CURTAILED MWH	CURTAILED MW
05/06	8	Economic	Local	SOLR	8	42
05/06	9	Economic	Local	SOLR	137	320
05/06	10	Economic	Local	SOLR	576	647
05/06	10	Economic	System	SOLR	2	
05/06	10	SelfSchCut	Local	SOLR	2	1
05/06	11	Economic	Local	SOLR	466	475
05/06	11	Economic	System	SOLR	7	40
05/06	11	SelfSchCut	Local	SOLR	3	4
05/06	12	Economic	Local	SOLR	337	412
05/06	12	Economic	System	SOLR	4	
05/06	12	SelfSchCut	Local	SOLR	9	6
05/06	13	Economic	Local	SOLR	385	483
05/06	13	SelfSchCut	Local	SOLR	3	
05/06	14	Economic	Local	SOLR	218	269
05/06	14	SelfSchCut	Local	SOLR	0	
05/06	15	Economic	Local	SOLR	311	402
05/06	15	SelfSchCut	Local	SOLR	6	20
05/06	16	Economic	Local	SOLR	284	359
05/06	16	SelfSchCut	Local	SOLR	6	20
05/06	17	Economic	Local	SOLR	281	348
05/06	17	SelfSchCut	Local	SOLR	10	8
05/06	18	Economic	Local	SOLR	131	164
05/06	18	Economic	Local	WIND	3	
05/06	18	Economic	System	SOLR	0	
05/06	18	SelfSchCut	Local	SOLR	2	6
05/06	19	Economic	Local	SOLR	39	38
05/06	19	Economic	Local	WIND	85	127
05/06	19	SelfSchCut	Local	SOLR	4	
05/06	20	Economic	Local	SOLR	5	
05/06	20	Economic	Local	WIND	161	208
05/06	21	Economic	Local	WIND	133	209

05/06	22	Economic	Local	WIND	98	187
05/06	23	Economic	Local	WIND	148	216
05/06	24	Economic	Local	WIND	183	221

The information contained in this report is preliminary and subject to change without notice. No inference, decision or conclusion should be made based on the information in this report or any series of these reports. All values are hourly average unless otherwise stated. Questions about this report should be directed to Short-Term Forecasting at ShortTermForecasting@caiso.com.